

Sherkston Community Centre Cistern System Annual Drinking Water Quality Report

Prepared on January 13, 2014
in accordance with O.Reg. 170/03
January 1, 2013 to December 31, 2013

Prepared by:



Casey Sharpe
Water/Wastewater Operator

Reviewed by:



Darlene Suddard
Environmental Compliance Supervisor

Approved by:



Doug Cressey
Utilities Supervisor

Approved by:



Ron Hanson
Director of Engineering and Operations

Drinking Water System number: 260092963
Drinking Water System category: Small Municipal Non-Residential
Owned and operated by: The Corporation of the City of Port Colborne

Sherkston Community Centre Cistern System Annual Drinking Water Quality Report

Introduction

The City of Port Colborne is required, under O.Reg.170/03 - *Drinking Water Systems*, to prepare an annual report detailing the operation of the Sherkston Community Centre Cistern System (SCCCS). The regulation specifies in Section 11 what the report must contain, and sets a February 28 deadline for having the report prepared and made available to the public.

Therefore, to ensure compliance with the regulation, this report is prepared in accordance with Section 11, and is available to the public on the City's website at www.portcolborne.ca, under the Water Quality link

Water Supply and Distribution

The Corporation of the City of Port Colborne (City) is the Owner of the Sherkston Community Centre Cistern System, which was the drinking water system for the City-owned Sherkston Community Centre (SCC) from January 1, 2013 to December 31, 2013. The City leases the SCC to the Sherkston Neighborhood Recreation Committee, who leased the facility to the District School Board of Niagara (DSBN) from January 1 to June 30, 2013. The DSBN operated the "Sherkston BRIDGE" program at the facility; during the 2012 – 2013 school year, there were twelve (12) grade 7 and 8 students and two (2) teachers at the facility on normal school days and times. The DSBN discontinued the "Sherkston BRIDGE" program at the SCC as of June 30th 2013.

The SCCC system consists of the following:

- One (1) Wilkinson Heavy PreCast Ltd. 9.7 m³ (3,500 USG) pre-cast concrete potable water cistern with stainless steel locking access hatch complete with perimeter gasket to provide positive seal against infiltration; a sufficient quantity of risers to provide positive assurance of protection from 100 year flood elevation; 1 ¼" 100 psi CSA Poly Pipe (ANSI/NSF 61) water supply line from the cistern to the building; 1 ½" PVC electrical conduit from the electrical panel to the cistern;
- One (1) NSF certified ultraviolet (UV) disinfectant system (Trojan UVMaxPro10 with "cool touch fan" with optional solenoid valve), complete with an ANSI/NSF certified 5-micron sediment and grit removal filter to protect the quartz sleeve

from abrasion and to ensure high transmissivity of the water. System includes: continuous UV intensity monitor; fail-safe solenoid valve (emergency shut-off valve) (alarm condition); thermal protection to prevent nuisance alarms and overheated water supply and; local display indicating status with audible alarm;

- One (1) submersible pump, ¾ HP, 10 gpm, 8 stage, 230 volt complete with cradle and with pressure switch suitable for use with hydro pneumatic pressure tanks for pump operational control;
- One (1) 35 gallon capacity hydro pneumatic pressure tank
- One (1) electrical powered autodialler that monitors the water level in the cistern, the UV system status, power supply etc. and automatically dials key City contacts in the event of an alarm.

Water Quality Monitoring

The City of Port Colborne is required to supply safe drinking water that meets the requirements of the Safe Drinking Water Act and associated regulations. To ensure the City meet these requirements, the City has assigned the following individuals as responsible persons for the SCCCS:

Table 1: Sherkston Community Centre Cistern System Responsible Persons

Position	Name	Phone number
Director of Engineering and Operations	Ron Hanson	905-835-2900 ext. 222
Utilities Supervisor	Doug Cressey	905-835-5079
Environmental Compliance Supervisor	Darlene Suddard	905-835-5079

The City has identified the Engineering and Operations Department as being responsible for the operation and maintenance of the Sherkston Community Centre Cistern System (SCCCS). The Public Works, Water Department operates under the Engineering and Operations Department, and is specifically responsible for the daily operation of the SCCCS. As such, the Water Department is responsible for assigning Certified Water Operators or MOE Trained Persons to conduct both the routine water quality sampling and testing and to conduct non-routine sampling (i.e., responding to adverse water quality incidents (AWQI)). These activities ensure the water quality meets the Ontario Drinking Water Quality Standards (O.Reg. 169/03) at all times and under all conditions. The Water Department also ensures that the Operational Checks, Sampling and Testing requirements specified in the Drinking Water Systems Regulation (O.Reg. 170/03) are conducted and recorded. If it is determined that the water quality or an operational parameter does not meet the regulated requirements or exceeds the

regulated limits, Certified Operators or MOE Trained Persons immediately implement corrective action to ensure the continued supply of safe drinking water. The operational checks, sampling and testing requirements which the City must conduct are outlined in Table 3.

Water Quality Test Results

As per the sampling and testing requirements detailed in Table 3, the City conducted the following sampling in the period of January 1, 2013 to December 31, 2013:

Microbiological Analysis

A total of 31 samples were collected and analyzed for the presence of *E.coli* and Total Coliforms (Table 4). *E.coli* and Total Coliforms were not detected in any of the treated water samples. To verify that the UV system was functioning properly, untreated water samples were collected from the pre filter tap on four separate occasions (Table 4). Total coliforms were detected on two occasions (4 counts/100ml and >5 counts/100ml) and there was one NDOGN result (No Data-total coliform/*E.coli* Plate Overgrown with Non-Target Bacteria) on one *E.coli* test. On all three occasions, the results from the treated water samples collected at the same time indicated that the UV system was operating effectively, as the samples showed that *E.coli* and total coliforms were non-detectable.

Operational Checks

On a twice-weekly basis, the City performed a site visit to monitor the system and ensure there were no issues. The cistern hatch was checked to ensure it was secure, the UV system was checked and UV statistics (lamp hours etc.) was recorded, the system pressure was recorded and the pump status (idle vs. running) was noted.

Lead Testing (Schedule 15.1) Results

The City is not required to test for lead, as the designated facility falls under the requirements of O.Reg. 243/07; as such, the DSBN is responsible for all lead testing activities at the facility.

Regulatory Non-Compliances

There were no instances of regulatory non-compliance in 2013.

Water System Upgrades

There were no upgrades or significant expenditures made during 2013, as the system was less than 2 years old.

Where to Obtain Additional Information

Copies of this annual report are available, free of charge, at the Engineering and Operations Department, 2nd Floor, City Hall - 66 Charlotte Street. It can also be downloaded from the internet at www.portcolborne.ca, under the “Water Quality” link. Copies may also be obtained by contacting the City numbers listed below.

Additionally, all laboratory test results are available either at the Engineering and Operations Department or at the Public Works office at 11 King Street. Copies may also be obtained by contacting the City numbers listed below.

Table 2: Contact Information for the City

Organization	Department	Phone Number
City of Port Colborne	Engineering and Operations Department	905-835-2900
	Public Works	905-835-5079

Table 3: Sherkston Community Centre Cistern System- Water Quality Sampling and Testing Requirements

Parameter	Sampling and Analysis	Water Quality Standards	Comments
Microbiological	As this system is supplied by transported water, that is stored in a sealed cistern, there is no regulatory requirement to collect samples for microbiological analysis. However, the City continues to collect a minimum of 2 samples of water per month and test for totalcoliforms and/or <i>E.coli</i> .	<ul style="list-style-type: none"> <i>E.coli</i> – NONE detected Total Coliforms – NONE detected 	<ul style="list-style-type: none"> An average of 2 samples per month Samples sent to an accredited laboratory for analysis Adverse results are immediately reported by the lab to the City

Table 4: Sherkston Community Centre Cistern System - Water Quality Sampling and Testing Results
January 1, 2013 – December 31, 2013

Parameter	Requirement	Number of samples	Results			Comments
			Range	Unit	Exceedances	
Microbiological Analysis – Treated Water						
<i>E. coli</i>	ND	24	ND	cfu/100 mL	0	Presence of <i>E.coli</i> indicates presence of fecal matter
Total Coliforms	ND	24	ND	cfu/100 mL	0	Presence of Total Coliforms indicates possible presence of pathogenic bacteria
Microbiological Analysis – Raw Water						
<i>E. coli</i>	N/A	4	ND- NDOGN	cfu/100 mL	N/A	Presence of <i>E.coli</i> indicates presence of fecal matter
Total Coliforms	N/A	4	ND-> 5	cfu/100 mL	2	Presence of Total Coliforms indicates possible presence of pathogenic bacteria

ND = non-detectable NDOGN = No Data-Total Coliform/ *E.coli* Plate Overgrown with Non-Target Bacteria (Adverse) N/A = Not applicable