

**Part III Form 2
Section 11. ANNUAL REPORT.**

Drinking-Water System Number:	260001643
Drinking-Water System Name:	Port Colborne Distribution System
Drinking-Water System Owner:	Corporation of the City of Port Colborne
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2006 – December 31, 2006

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [x] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> Copies of all reports are available at City Hall, 66 Charlotte Street, Port Colborne. and at the Public Works office, 11 King Street, Port Colborne. </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
---	--

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
n/a	n/a

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No []
n/a

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

The City of Port Colborne water supply is the Welland Canal. The water is treated at the Port Colborne Water Treatment Plant which is operated by the Regional Municipality of Niagara, Public Works Department, Water & Wastewater Division. The City purchases the water from the Region of Niagara on a volume basis and distributes it through the City operated distribution system. The distribution is a Class 1 system. Details of the distribution system are available from the City of Port Colborne Operational Services Public Works Department.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite (-12%)

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

2006 Capital Investments for Watermain Replacement

Contract #2006-3C – Ash/Elm/Fielden/Watermain

Unfinanced/Unexpended Balance	\$ 391.76
Salaries & Wages	24,114.26
Employee Benefits	8,925.30
Advertising	205.80
Engineering Fees	1,366.05
Contract Services	<u>304,261.34</u>

Total	\$339,264.51
--------------	---------------------

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
June 1	Total Coliform	1	CFU 100 ml	Resample & Test	June 1
June 3*	Total Coliform*	122	CFU 100ml	Resample & Test	June 3
	Background*	>200	CFU 100ml	Resample & Test	June 3
June 4	Total Coliform	1	CFU 100ml	Resample & Test	June 4
June 8	Total Coliform	2	CFU 100ml	Resample & Test	June 8
June 29	Total Coliform	3	CFU 100ml	Resample & Test	June 29
July 11	Total Coliform	3	CFU 100ml	Resample & Test	July 11
Sept 7	Total Coliform	2	CFU 100ml	Resample & Test	Sept 7

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	n/a	n/a	n/a	n/a	n/a
Treated	n/a	n/a	n/a	n/a	n/a
Distribution	679	0	0 - 122	113	0 - 53

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)

***NOTE:** For continuous monitors use 8760 as the number of samples.*

Turbidity	1629	0.05 - 1.55
Chlorine	1629	0.08 - 1.35
Fluoride (If the DWS provides fluoridation)	n/a	

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Lead	2006	0.0001	mg/L	none
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				

Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				
THM (NOTE: show latest annual average)	2006 Average	0.02375	mg/L	none
Temphos				
Terbufos				

Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)